

CORTEX

Core monitoring techniques and
experimental validation and demonstration

Welcome and project overview

Final CORTEX workshop

Online

Prof. Christophe Demazière – Chalmers University of Technology

demaz@chalmers.se



This project has received funding from the Euratom research and training programme 2014-2018 under grant agreement No 754316.

Agenda

June 21, 2021 – CORTEX in a nutshell

08:30 – 08:45: Welcome and project overview

(C. Demazière, Chalmers University of Technology, Sweden)

08:45 – 09:00: Theoretical basis of neutron noise and core diagnostics

(C. Demazière, Chalmers University of Technology, Sweden)

09:00 – 11:00: Development, verification and validation of neutron noise-specific modelling tools

09:00 – 09:45: Overview of the modelling tools used or developed in CORTEX and their verification

(P. Vinai, Chalmers University of Technology, Sweden)

09:45 – 10:15: Break

10:15 – 11:00: Overview of the validation exercises undertaken in CORTEX

(M. Hursin, Ecole Polytechnique Fédérale de Lausanne, Switzerland)

11:00 – 11:45: Development of advanced signal analysis and machine learning techniques in support to core diagnostics

(S. Kollias, University of Lincoln, United Kingdom)

11:45 – 12:30: Questions and wrap-up

(C. Demazière, Chalmers University of Technology, Sweden)



Agenda

June 22, 2021 – **Neutron noise-based core diagnostics applied to commercial nuclear reactors**

08:30 – 08:35: **Welcome and introduction**

(J. Herb, Gesellschaft für Anlagen- und Reaktorsicherheit (GRS) gGmbH, Germany)

08:35 – 09:05: **Required instrumentation and data acquisition system**

(G. Girardin, Kernkraftwerk Gösge-Daniken AG, Switzerland)

09:05 – 09:15: **Required data for modelling the reactor transfer function**

(C. Demazière, Chalmers University of Technology, Sweden)

09:15 – 09:45: **Necessary signal processing**

(C. Montalvo, Universidad Politécnica de Madrid, Spain)

09:45 – 10:15: Break

10:15 – 11:45: **Machine learning architectures versus diagnostic tasks**

(G. Leontidis, University of Aberdeen, United Kingdom; M. Yu, University of Lincoln, United Kingdom;
G. Alexandridis, Institute of Communication and Computer Systems, Greece)

11:45 – 12:15: **Examples of applications on commercial reactors within CORTEX**

(J. Herb, Gesellschaft für Anlagen- und Reaktorsicherheit (GRS) gGmbH, Germany)

12:15 – 12:45: **Questions and wrap-up**

(J. Herb, Gesellschaft für Anlagen- und Reaktorsicherheit (GRS) gGmbH, Germany;
C. Demazière, Chalmers University of Technology, Sweden)



Practicalities

- Turn off your camera and you microphone by default
- In case of question, use “Raise your hand” and turn on your camera and microphone when instructed by the moderator of the meeting
- Meeting will be recorded




Introduction and background



Introduction and background

- Fluctuations always existing in dynamical systems even at steady state-conditions:




Conceptual illustration of the possible time-dependence of a measured signal from a dynamical system

$$X(\mathbf{r}, t) = X_0(\mathbf{r}, t) + \delta X(\mathbf{r}, t)$$

Introduction and background


- Fluctuations always existing in dynamical systems even at steady state-conditions:



Conceptual illustration of the possible time-dependence of a measured signal from a dynamical system


$$X(\mathbf{r}, t) = X_0(\mathbf{r}, t) + \delta X(\mathbf{r}, t)$$

actual
signal



Introduction and background

- Fluctuations always existing in dynamical systems even at steady state-conditions:




Conceptual illustration of the possible time-dependence of a measured signal from a dynamical system

$$X(\mathbf{r}, t) = \underbrace{X_0(\mathbf{r}, t)}_{\text{signal trend or mean}} + \delta X(\mathbf{r}, t)$$

signal
trend or mean

Introduction and background

- Fluctuations always existing in dynamical systems even at steady state-conditions:



Conceptual illustration of the possible time-dependence of a measured signal from a dynamical system

$$X(\mathbf{r}, t) = X_0(\mathbf{r}, t) + \delta X(\mathbf{r}, t)$$

fluctuations
or “noise”

- Fluctuations carrying some valuable information about the system dynamics




Introduction and background

- Fluctuations could be used for “diagnostics”, i.e.:

- Early detection of anomalies
- Estimation of dynamical system characteristics


... even if the system is operating at steady-state conditions

- Fluctuations in the neutron density in nuclear reactors can be used for core diagnostics and monitoring



Introduction and background


- Neutron detectors present both as in-core and ex-core:



- Advantage: “sense” perturbations even far away from the perturbations
- Disadvantage: western-type reactors do not always contain many in-core neutron detectors


Introduction and background

- Neutron noise diagnostics requires establishing relationships between neutron detectors and possible perturbations
 - The “reactor transfer function” $G(\mathbf{r}, \mathbf{r}_p, \omega)$ needs to be determined




Introduction and background

- But noise diagnostics requires the inversion of the reactor transfer function $G(\mathbf{r}, \mathbf{r}_p, \omega)$



Introduction and background

- But noise diagnostics requires the inversion of the reactor transfer function $G(\mathbf{r}, \mathbf{r}_p, \omega)$




- Machine learning could be used for that purpose
- Unfolding possible even if very few detectors available (due to the spatial correlations existing between a localized perturbation and its effect throughout the nuclear core)

CORTEX project overview



CORTEX project overview

- Overall principle of the Horizon 2020 CORTEX project:



More info at:
cortex-h2020.eu

CORTEX project overview

- Project aims for CORTEX:
 - **WP1: Developing high fidelity tools for simulating stationary fluctuations**
(leader: P.Vinai, Chalmers University of Technology, Sweden)
 - **WP2: Validating those tools against experiments to be performed at research reactors**
(leader: M. Hursin, Ecole Polytechnique Fédérale de Lausanne, Switzerland)
 - **WP3: Developing advanced signal processing and machine learning techniques** (to be combined with the simulation tools)
(leader: S. Kollias, University of Lincoln, United Kingdom)
 - **WP4: Demonstrating the proposed methods for both on-line and off-line core diagnostics and monitoring**
(leader: J. Herb, Gesellschaft für Anlagen- und Reaktorsicherheit (GRS) gGmbH, Germany)
 - **WP5: Disseminating the knowledge gathered from within the project to stakeholders in the nuclear sector**
(leader: C. Demazière, Chalmers University of Technology, Sweden)



CORTEX project overview

- CORTEX project participants:
 - Project led and coordinated by Chalmers University of Technology
 - 18 European organizations involved in the project:
 - CEA and LGI Consulting (France)
 - Centre for Energy Research, Hungarian Academy of Sciences – MTA EK (Hungary)
 - EPFL, KKG, PSI (Switzerland)
 - GRS, ISTec, TIS, PEL, TU Dresden and TU Munich (Germany)
 - Institute of Communication & Computer Systems - National Technical University of Athens (Greece)
 - UJV (Czech Republic)
 - University of Lincoln (UK)
 - UPM and UPV (Spain)



CORTEX project overview

- CORTEX project participants:
 - 2 non-European organizations formally involved in the project:
 - KURRI (Japan)
 - AMS Corp (USA)
 - 7 additional organizations involved in the Advisory End-User Group:
 - IRSN (France)
 - KKG (Switzerland)
 - PEL (Germany)
 - Ringhals (Sweden)
 - Tractebel (Belgium)
 - CNAT (Spain)
 - Framatome GmbH (Germany)
 - Westinghouse Electric Sweden AB (Sweden)
 - NRG (the Netherlands)



CORTEX project overview

- Project started on September 1st, 2017 and ends on August 31st, 2021
- More than 70 researchers involved
- 25 deliverables to the European Commission
- 23 presentations made at conferences and workshops
- 5 poster presented at conferences
- 35 peer-reviewed conference papers
- 15 peer-reviewed journal publications
- 8 training courses/hands-on training sessions offered



Theoretical basis of neutron noise and core diagnostics



Theoretical basis of neutron noise and core diagnostics

- Neutron noise dating back from the early days of nuclear power (oscillator experiments in the Clinton Pile at Oak Ridge National Laboratories, USA in late 40ies)
- First applications in commercial reactors:
 - Core-barrel vibrations at the Palisades plant, USA (1975)
 - Estimation of in-core coolant velocity in German BWRs (1979)



Theoretical basis of neutron noise and core diagnostics

- Modelling of the neutron noise can be done using the neutron transport equation (Boltzmann equation):

$$\begin{aligned} & \frac{1}{v(E)} \frac{\partial}{\partial t} \psi(\mathbf{r}, \boldsymbol{\Omega}, E, t) \\ &= -\boldsymbol{\Omega} \cdot \boldsymbol{\nabla} \psi(\mathbf{r}, \boldsymbol{\Omega}, E, t) - \Sigma_t(\mathbf{r}, E, t) \psi(\mathbf{r}, \boldsymbol{\Omega}, E, t) \\ &+ \int_{(4\pi)} \int_0^\infty \Sigma_s(\mathbf{r}, \boldsymbol{\Omega}' \rightarrow \boldsymbol{\Omega}, E' \rightarrow E, t) \psi(\mathbf{r}, \boldsymbol{\Omega}', E', t) d^2\boldsymbol{\Omega}' dE' \\ &+ \frac{1}{4\pi} \int_{-\infty}^t \int_0^\infty \nu(E') \Sigma_f(\mathbf{r}, E', t') \phi(\mathbf{r}, E', t') \left[(1 - \beta) \chi^p(E) \delta(t - t') + \sum_{i=1}^{N_d} \chi_i^d(E) \lambda_i \beta_i e^{-\lambda_i(t-t')} \right] dt' dE' \end{aligned}$$

- A model to represent the effect of a given perturbation onto the macroscopic cross-section is required



Theoretical basis of neutron noise and core diagnostics

- Modelling of the effect of the cross-section perturbations onto the neutron flux can be done in several ways:
 - Low/high order in angle
 - Low/high order in space
 - Low/high order in energy
 - Time- or frequency-domain
 - Deterministic methods or probabilistic methods (Monte Carlo)
- See WPI presentation titled “Overview of the modelling tools used or developed in CORTEX and their verification”
- See WP2 presentation titled “Overview of the validation exercises undertaken in CORTEX”



Theoretical basis of neutron noise and core diagnostics

- For diagnostic purposes, one needs to check that the induced neutron noise is significantly different, depending on the type of perturbation and its location
 - Examination of the amplitude and phase of the neutron noise usually allows differentiating the type of perturbation
 - Nevertheless, some more intricate responses can arise in some cases
 - Requires a faithful modelling of the reactor transfer function
 - For the identification of the location of a perturbation, an appreciable deviation from point-kinetics is required



Theoretical basis of neutron noise and core diagnostics

- Point-kinetic component of the neutron noise:

Using the factorization:


$$\phi(\mathbf{r}, t) = P(t) \cdot \psi(\mathbf{r}, t)$$

with

$P(t)$ amplitude factor
 $\psi(\mathbf{r}, t)$ shape function

such that

$$\frac{\partial}{\partial t} \int \phi_0(\mathbf{r}) \psi(\mathbf{r}, t) d^3\mathbf{r} = 0$$



Theoretical basis of neutron noise and core diagnostics

- Point-kinetic component of the neutron noise:

One obtains in first order:


$$\delta\phi(\mathbf{r}, t) = \delta P(t) \phi_0(\mathbf{r}) + \delta\psi(\mathbf{r}, t)$$

where one assumed:

$$P_0 = 1$$

$$\psi(\mathbf{r}, t = 0) = \phi_0(\mathbf{r})$$

- Point-kinetic response: $\delta P(t) \phi_0(\mathbf{r})$
- “Space-dependent” response: $\delta\psi(\mathbf{r}, t)$



Theoretical basis of neutron noise and core diagnostics

- Point-kinetic component of the neutron noise:

The fluctuations of the amplitude factor are further given, in the frequency domain, as:

$$\delta P(\omega) = G_0(\omega) \delta \rho(\omega)$$

with

$$G_0(\omega) = \frac{1}{i\omega \left(\Lambda_0 + \frac{\beta}{i\omega + \lambda} \right)}$$

zero-power reactor transfer function

(better name: *point-kinetic* zero-power reactor transfer function)



Theoretical basis of neutron noise and core diagnostics

- The ability to localize anomalies from very few detector readings requires a “sufficient” deviation from point-kinetics
 - See WP3 presentation titled “Development of advanced signal analysis and machine learning techniques in support to core diagnostics”
 - See WP4 presentations tomorrow “Neutron noise-based core diagnostics applied to commercial nuclear reactors”



Theoretical basis of neutron noise and core diagnostics





Illustration of the difference between the point-kinetic component and the total induced neutron noise in the frequency domain at 1 Hz, for a perturbation located at -30 cm from the centre of a nuclear core of size 300 cm.

Conclusions



Conclusions

- CORTEX methodology relying on a cross-disciplinary expertise in:
 - Reactor physics, dynamics, and modelling
 - Experimental reactor physics
 - Plant measurements
 - Signal processing and analysis
 - Artificial Intelligence and Machine Learning
- Main purpose of the workshop: summarize the main findings and their implications for core monitoring in commercial reactors



CORTEX

Core monitoring techniques and
experimental validation and demonstration

Welcome and project overview

Final CORTEX workshop

Online

Prof. Christophe Demazière – Chalmers University of Technology

demaz@chalmers.se



This project has received funding from the Euratom research and training programme 2014-2018 under grant agreement No 754316.